



## GHXV.EX15733 Proportioners, Foam Concentrate

[Page Bottom](#)

### Proportioners, Foam Concentrate

[See General Information for Proportioners, Foam Concentrate](#)**FIRETECH EQUIPMENT & SYSTEMS PRIVATE LTD**

EX15733

24 SARDAR PRATAP SINGH IND ESTATE 3  
L B S MARG  
BHADUP (W)  
MUMBAI, Maharashtra 400078 INDIA

**BLADDER TANK AND RATIO-FLOW CONTROLLER INVESTIGATED TO UL 162**

53 to 3963 gal capacity ASME for vertical and horizontal installation

Following are equivalent length valves for the controllers (Models BTFP) based on a roughness factor of 130 and schedule 40 steel pipes.

Controller Size In.	Equivalent Length Ft
2	22.0
3	17.5
4	29.3
6	24.9
8	23.0

Refer to the individual foam concentrate Listings for operating limitations with specific combinations of foam concentrates and proportioner.

[Last Updated](#) on 2013-10-21[Questions?](#)[Print this page](#)[Terms of Use](#)[Page Top](#)

© 2017 UL LLC

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2017 UL LLC".