



GFXX.EX16288 Foam Monitors

[Page Bottom](#)

Foam Monitors

[See General Information for Foam Monitors](#)**FIRETECH EQUIPMENT & SYSTEMS PRIVATE LTD**

EX16288

24 SARDAR PRATAP SINGH IND ESTATE 3

L B S MARG

BHADUP (W)

MUMBAI, Maharashtra 400078 INDIA

Foam monitors for application of firefighting foam solutions for models, types, inlet pressures and solution discharge flow rates as shown:

Monitor Model	Nozzle Model	Type	Monitor Inlet Pressure, psi	Solution Discharge Flow Rate, gpm
WFM-750-80	AFM-750-80	C	100	750
HFLR-FM-150	AFM-VF-150 Set at 1000	B, C (JRC-VF-65)	100	1000
HFLR-FM-150	AFM-VF-150 Set at 1500	B, C (JRC-VF-65)	100	1500
HFLR-FM-150	AFM-VF-150 Set at 2000	B, C (JRC-VF-65)	100	2000

A - Oscillating

B - Nonoscillating

C - Self-inducting

D - Non-self-inducting

Refer to the individual foam concentrate Listings for operating limitations with specific combinations of foam concentrates and monitors.

[Last Updated](#) on 2015-10-30[Questions?](#)[Print this page](#)[Terms of Use](#)[Page Top](#)

© 2017 UL LLC

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2017 UL LLC".